



Notes for installing & debugging module-like electronic amplifier:  
 1. Only allow connection under power-free status.  
 2. Must use shield cable for given value, solenoid & speed signal.  
 3. Both ends of a shield cable must be grounded.